



Confirmation

Eurofins Product Testing A/S confirms that a sample of a construction adhesive with the name:

ResiFIX BR385SF Pure Epoxy
supplied by
Apolo MEA Befestigungssysteme GmbH

showed low VOC contents in a test in accordance with ASTM D 2369 - 10 as specified in LEED credit EQ 4.1 (adhesives and sealants).

VOC contents were below the limit value specified as 70 grams VOC minus water per liters.

The test has been performed in July 2012, see test report no. G15982E.
Water content was specified by manufacturer.

With this confirmation, use of product ResiFIX BR385SF Pure Epoxy may qualify for fulfillment of LEED credit EQ 4.1 (adhesives and sealants).

28.04.2014

Søren Ryom Villadsen
Analytical Service Manager

Eurofins Product Testing A/S
Smedeskovvej 38
DK 8464 Galten / Denmark

Tel +45 70 22 42 76
Fax +45 70 22 42 75

www.product-testing.eurofins.com