

Kiwa K26261/01 (Consideraciones Apolo)

La homologación Kiwa certifica que la abrazadera Abranyl® Max es adecuada para la sujeción de tubos de plástico y cobre para la conducción de **agua fría y caliente hasta 90°C.**

The Kiwa certification guarantees that Abranyl® Max can be used for fastening plastic and copper pipes in installations of Cold and Hot water up to 90°C.



Resistencia abrazaderas Clamp loads			
Abranyl® Max (mm)	Resistencia Certificada por Kiwa condiciones normales 23°C Tension loads at 23°C Certified by Kiwa laboratories (kg)	Valor recomendado aplicación a 90°C Tension loads at 90°C recommended by Apolo (kg)	Valor rotura Ultimate load (kg)
15 - 18	15	10	40
20 - 25	19	12	45
26 - 32	24	16	
35 - 42	30	20	70

En condiciones normales 23°C:

Orientación Horizontal

- Instalaciones eléctricas: espaciado máximo recomendado de 1,5 m
- Instalaciones hidrosanitarias: espaciado máximo recomendado de 1 m

Orientación Vertical

- Instalaciones eléctricas: espaciado máximo recomendado de 2 m
- Instalaciones hidrosanitarias: espaciado máximo recomendado de 1,3 m

At 23°C

Horizontal position

- Electrical installations: maximum distance of 1.5m recommended.
- Plumbing installations: maximum distance of 1 m recommended.

Vertical position

- Electrical installations: maximum distance of 2m recommended.
- Plumbing installations: maximum distance of 1.3 m recommended

En Instalaciones Hidrosanitarias a 90°C:

- Orientación Horizontal: espaciado máximo recomendado de 0,7 m
- Orientación Vertical: espaciado máximo recomendado de 1 m

At 90°C

- Horizontal position: maximum distance of 0.7 m recommended.
- Vertical position: maximum distance of 1 m recommended.

Certificate

Number	K 26261/01	Replaces	-
Issued	2005-01-01	Dated	-

Product Certificate


Plastic pipe clips for copper and plastic water pipes

Based on pre-certification tests as well as periodic inspections by Kiwa, the products referred to in this certificate and marked with the Kiwa-mark as indicated under 'Marking', supplied by

Apolo Fijaciones y Herramientas S.L.

may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K506/01 "Plastic pipe clips for copper and plastic water pipes".

Kiwa N.V.



ing. B. Meekma
Director,
Certification and Inspection

This certificate is issued in accordance with the Kiwa-Regulations for Product Certification.

This certificate consists of 3 pages.

Publication of the certificate is allowed.

Kiwa N.V.
Certification and Inspection
Sir W. Churchill-laan 273
Postbus 70
2280 AB Rijswijk
The Netherlands

Telephone +31 70 41 44 400
Telefax +31 70 41 44 420
Internet www.kiwa.nl

Company

Apolo Fijaciones y Herramientas S.L.
Garrotxa 10-22
08211 CASTELLAR DEL VALLÈS
Spain

Telephone +34 93 747 33 33
Telefax +34 93 747 33 37
Internet www.apolo.es